



2022年9月 永瀬ダム 自動濁度装置 測定結果一覧表

※濁度測定器は、ホルマジン標準液 (FTU) を使用して校正しています。

自動濁度計設置場所

| 水深 | 1日 | | 2日 | | 3日 | | 4日 | | 5日 | | 6日 | | 7日 | | 8日 | | 9日 | | 10日 | | 11日 | | 12日 | | 13日 | | 14日 | | 15日 | |
|-----|------|------|------|------|------|------|------|------|------|-------|------|-------|------|-------|------|-------|------|-------|------|------|------|-------|------|-------|------|-------|------|-------|------|------|
| | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 | 水温 | 濁度 |
| 0.5 | 24.8 | 1.0 | 24.6 | 1.0 | 24.4 | 1.2 | 24.1 | 1.0 | 23.7 | 1.0 | 23.9 | 1.8 | 23.5 | 2.2 | 23.1 | 1.5 | 22.9 | 1.3 | 22.5 | 1.2 | 22.3 | 1.2 | 22.7 | 1.2 | 23.1 | 1.3 | 23.4 | 1.5 | 23.8 | 1.5 |
| 1 | 24.9 | 1.0 | 24.7 | 1.0 | 24.7 | 1.2 | 24.1 | 1.2 | 23.9 | 1.2 | 24.0 | 1.8 | 23.6 | 2.2 | 23.2 | 1.5 | 23.0 | 1.5 | 22.5 | 1.5 | 22.4 | 1.2 | 23.0 | 1.2 | 23.3 | 1.5 | 23.7 | 1.5 | 23.9 | 1.5 |
| 2 | 25.1 | 1.2 | 25.1 | 1.2 | 25.3 | 1.5 | 24.5 | 1.2 | 24.1 | 1.2 | 24.4 | 1.8 | 23.8 | 2.9 | 23.4 | 1.8 | 23.2 | 1.5 | 22.5 | 1.5 | 22.5 | 1.3 | 23.4 | 1.5 | 23.9 | 1.5 | 24.1 | 2.2 | 24.3 | 2.2 |
| 3 | 25.2 | 1.2 | 25.2 | 1.2 | 25.4 | 1.2 | 24.6 | 1.3 | 24.0 | 1.2 | 24.4 | 1.5 | 23.8 | 2.4 | 23.4 | 1.8 | 23.1 | 1.5 | 22.5 | 1.5 | 22.5 | 2.0 | 23.5 | 3.9 | 23.9 | 4.3 | 24.1 | 4.8 | 24.4 | 5.8 |
| 4 | 25.0 | 1.2 | 24.9 | 1.2 | 24.7 | 1.3 | 24.0 | 1.2 | 23.9 | 1.0 | 23.8 | 1.2 | 23.3 | 1.5 | 23.2 | 1.5 | 23.0 | 1.5 | 22.5 | 3.1 | 22.4 | 4.8 | 23.0 | 5.8 | 23.7 | 7.5 | 23.6 | 8.9 | 24.0 | 10.8 |
| 5 | 24.3 | 1.2 | 24.3 | 1.2 | 24.0 | 1.0 | 23.5 | 1.2 | 23.4 | 1.0 | 23.2 | 1.2 | 23.0 | 1.2 | 22.8 | 1.5 | 22.7 | 1.8 | 22.3 | 7.0 | 22.2 | 13.4 | 22.6 | 14.6 | 23.1 | 17.6 | 23.1 | 16.3 | 23.1 | 16.5 |
| 6 | 23.8 | 1.0 | 23.6 | 1.0 | 23.3 | 1.0 | 23.1 | 1.2 | 22.9 | 1.2 | 22.7 | 1.2 | 22.5 | 1.2 | 22.5 | 2.9 | 22.3 | 6.8 | 22.1 | 17.0 | 22.0 | 23.1 | 22.2 | 22.0 | 22.4 | 21.8 | 22.5 | 20.8 | 22.4 | 19.3 |
| 7 | 23.3 | 1.0 | 23.2 | 1.0 | 22.8 | 1.0 | 22.8 | 1.0 | 22.5 | 1.2 | 22.4 | 1.0 | 22.2 | 3.1 | 22.3 | 5.6 | 22.2 | 23.5 | 21.8 | 24.1 | 21.7 | 23.7 | 21.8 | 22.9 | 21.8 | 22.7 | 21.9 | 21.4 | 21.9 | 20.5 |
| 8 | 22.9 | 1.0 | 22.8 | 1.0 | 22.6 | 1.2 | 22.5 | 1.2 | 22.4 | 1.2 | 22.1 | 1.0 | 22.2 | 17.8 | 22.1 | 13.6 | 21.9 | 27.5 | 21.6 | 26.7 | 21.5 | 23.1 | 21.6 | 21.4 | 21.6 | 19.1 | 21.6 | 19.9 | 21.6 | 18.2 |
| 9 | 22.4 | 1.2 | 22.5 | 1.2 | 22.4 | 1.2 | 22.3 | 1.0 | 22.2 | 1.2 | 21.9 | 1.2 | 22.0 | 11.0 | 21.9 | 23.1 | 21.6 | 29.0 | 21.5 | 25.6 | 21.4 | 22.4 | 21.4 | 19.9 | 21.4 | 18.4 | 21.4 | 16.3 | 21.4 | 15.1 |
| 10 | 22.1 | 1.2 | 22.3 | 1.5 | 22.2 | 1.2 | 22.2 | 1.2 | 22.1 | 1.2 | 21.6 | 1.2 | 21.8 | 36.2 | 21.7 | 30.5 | 21.5 | 24.3 | 21.3 | 22.7 | 21.3 | 21.6 | 21.3 | 18.9 | 21.2 | 14.4 | 21.2 | 13.8 | 21.3 | 12.7 |
| 12 | 21.4 | 2.6 | 21.9 | 1.5 | 22.0 | 1.8 | 21.8 | 2.2 | 21.3 | 3.4 | 21.0 | 6.8 | 21.4 | 25.8 | 21.4 | 30.0 | 21.3 | 28.1 | 21.2 | 23.5 | 21.2 | 21.2 | 21.1 | 16.1 | 21.0 | 15.3 | 21.1 | 12.1 | 21.1 | 12.7 |
| 14 | 20.1 | 9.8 | 20.6 | 6.7 | 20.7 | 5.8 | 19.9 | 8.1 | 19.5 | 12.4 | 18.7 | 12.4 | 21.0 | 36.4 | 21.2 | 32.9 | 21.2 | 28.4 | 21.0 | 26.5 | 20.9 | 23.5 | 20.8 | 22.4 | 20.8 | 20.3 | 21.0 | 17.8 | 20.9 | 17.2 |
| 16 | 18.7 | 18.4 | 19.1 | 16.5 | 18.9 | 15.3 | 18.6 | 17.0 | 18.1 | 16.3 | 17.8 | 15.1 | 20.7 | 6.2 | 20.9 | 26.5 | 20.8 | 22.9 | 20.8 | 20.8 | 20.7 | 24.3 | 20.6 | 19.5 | 20.7 | 18.2 | 20.7 | 18.6 | 20.8 | 15.7 |
| 18 | 18.0 | 22.9 | 18.1 | 21.4 | 18.2 | 19.5 | 18.0 | 21.0 | 17.7 | 20.3 | 17.3 | 17.2 | 19.5 | 12.9 | 20.1 | 12.7 | 20.1 | 12.7 | 19.9 | 13.4 | 20.4 | 11.7 | 20.0 | 11.0 | 20.1 | 10.0 | 20.1 | 10.2 | 20.2 | 9.8 |
| 20 | 17.6 | 20.8 | 17.8 | 22.4 | 17.7 | 20.5 | 17.6 | 20.8 | 17.4 | 18.9 | 17.1 | 14.6 | 18.4 | 18.4 | 18.5 | 15.7 | 18.5 | 16.1 | 18.7 | 17.0 | 18.7 | 14.6 | 18.7 | 14.0 | 18.7 | 12.7 | 18.7 | 12.5 | 18.8 | 11.7 |
| 25 | 17.1 | 16.5 | 17.2 | 18.6 | 17.2 | 15.7 | 17.2 | 14.6 | 17.1 | 13.4 | 16.9 | 12.4 | 17.4 | 15.3 | 17.6 | 15.3 | 17.4 | 14.2 | 17.4 | 13.2 | 17.6 | 12.1 | 17.5 | 11.5 | 17.5 | 10.5 | 17.4 | 9.8 | 17.5 | 10.0 |
| 30 | 17.0 | 24.6 | 17.0 | 19.3 | 17.0 | 21.4 | 16.9 | 16.5 | 16.9 | 14.4 | 16.7 | 16.7 | 17.1 | 12.7 | 17.1 | 11.7 | 17.1 | 10.6 | 17.1 | 9.6 | 17.1 | 9.1 | 17.1 | 7.2 | 17.1 | 8.1 | 17.1 | 8.3 | 17.2 | 7.0 |
| 35 | 16.8 | 15.7 | 16.8 | 17.0 | 16.8 | 17.6 | 16.7 | 25.8 | 16.7 | 17.4 | 16.6 | 14.6 | 16.8 | 14.8 | 16.9 | 13.4 | 16.9 | 10.6 | 16.9 | 9.8 | 16.8 | 8.3 | 16.8 | 9.8 | 16.8 | 8.7 | 16.9 | 8.3 | 16.9 | 8.7 |
| 40 | 16.7 | 11.3 | 16.7 | 10.6 | 16.7 | 10.6 | 16.2 | 13.2 | 18.1 | 313.3 | 16.9 | 145.4 | 16.4 | 137.8 | 16.3 | 107.8 | 16.3 | 118.2 | 16.3 | 95.0 | 16.3 | 105.9 | 16.3 | 100.7 | 16.3 | 104.5 | 16.3 | 102.6 | 16.3 | 97.5 |



▲永瀬ダム周辺 位置図



▲自動濁度計 全景

永瀬ダム堰堤上流付近に台船を浮かべ、その上に自動で濁度を取得する装置を設置しています。

毎日朝9時になると測定器を沈め、設定された深度における濁度を計測しています。

m