


2025 年 1 月 永瀬ダム 自動濁度装置 測定結果一覧表

※濁度測定器は、ホルマジン標準液（FTU）を使用して校正しています。

自動濁度計設置場所

	1 日		2 日		3 日		4 日		5 日		6 日		7 日		8 日		9 日		10 日		11 日		12 日		13 日		14 日		15 日			
水深	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度		
0.5	9.1	1.3	9.0	2.4	8.9	1.3	8.8	1.3	8.7	1.3	8.6	1.2	8.5	1.0	8.4	1.2	8.3	1.3	8.2	1.3	8.0	1.3	8.0	1.3	7.9	1.3	7.9	1.3	7.9	1.2		
1	9.1	1.3	9.0	1.6	8.9	1.0	8.8	1.3	8.7	1.3	8.6	1.3	8.5	1.0	8.4	1.2	8.3	1.2	8.2	1.3	8.0	1.6	8.0	1.2	7.9	1.3	7.9	1.3	7.9	1.3		
2	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.2	8.6	1.3	8.5	0.8	8.4	1.0	8.3	1.2	8.2	1.3	8.0	1.3	8.0	1.3	7.9	1.3	7.9	1.3	7.9	1.3		
3	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.3	8.6	1.3	8.5	1.2	8.4	1.0	8.3	1.0	8.2	1.6	8.0	1.3	8.0	1.3	7.9	1.3	7.9	1.3	7.9	1.6		
4	9.1	1.6	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.2	8.6	1.3	8.5	1.3	8.4	1.0	8.3	1.0	8.2	1.3	8.0	1.3	8.0	1.3	7.9	1.6	7.9	1.3	7.9	1.6		
5	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.3	8.6	1.3	8.5	1.0	8.4	1.2	8.3	1.3	8.2	1.3	8.0	1.2	8.0	1.0	7.9	1.3	7.9	1.3	7.9	1.3		
6	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.3	8.6	1.3	8.5	1.0	8.4	1.0	8.3	1.0	8.2	1.6	8.0	1.3	8.0	1.3	7.9	2.0	7.9	1.3	7.9	1.3		
7	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.6	8.6	1.2	8.5	1.0	8.4	1.0	8.3	1.2	8.2	1.3	8.0	1.6	8.0	1.3	7.9	1.6	7.9	1.3	7.9	1.3		
8	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.2	8.7	1.3	8.6	1.3	8.6	1.0	8.4	1.0	8.3	1.3	8.2	1.3	8.0	1.3	8.0	1.3	7.9	1.6	7.9	1.6	7.9	1.3		
9	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.3	8.6	1.3	8.6	1.0	8.4	1.2	8.3	1.2	8.2	1.3	8.0	1.3	8.0	1.3	7.9	1.6	7.9	1.3	7.9	1.6		
10	9.1	1.3	9.0	1.3	8.9	1.3	8.8	1.3	8.7	1.3	8.6	1.0	8.6	1.3	8.4	1.0	8.3	1.2	8.2	1.3	8.0	1.3	8.0	1.2	7.9	1.3	7.9	1.3	7.9	1.6		
12	9.1	1.3	9.0	1.6	8.9	1.6	8.8	1.3	8.7	1.3	8.6	1.3	8.6	1.0	8.4	1.0	8.3	1.0	8.2	1.6	8.0	1.3	8.0	1.3	7.9	1.6	7.9	1.3	7.9	1.6		
14	9.1	1.6	9.0	2.0	8.9	2.0	8.8	1.3	8.7	1.3	8.6	1.3	8.6	2.0	8.4	1.0	8.3	1.3	8.2	1.6	8.0	1.3	8.0	1.2	7.9	1.6	7.9	1.6	7.9	1.8		
16	9.1	1.8	9.0	2.4	8.9	2.2	8.8	1.3	8.7	1.3	8.6	1.8	8.5	2.4	8.4	1.3	8.3	1.3	8.2	1.6	8.0	1.3	8.0	2.0	7.9	1.8	7.9	1.8	7.8	2.0		
18	9.0	2.4	8.9	3.0	8.8	2.4	8.8	1.3	8.7	1.6	8.6	2.7	8.4	2.4	8.4	2.2	8.3	2.0	8.1	2.7	8.0	1.3	8.0	2.0	7.9	2.4	7.9	2.0	7.8	2.2		
20	9.0	3.7	8.9	3.5	8.8	2.7	8.8	3.0	8.6	3.9	8.6	3.5	8.4	3.2	8.4	2.4	8.3	3.0	8.1	2.9	8.0	2.4	8.0	2.9	7.9	3.5	7.9	2.7	7.7	3.7		
25	8.9	4.1	8.7	4.1	8.7	4.3	8.6	4.3	8.5	4.5	8.4	5.6	8.3	5.4	8.2	4.5	8.1	4.1	8.1	4.3	7.9	3.9	7.8	5.4	7.7	4.5	7.7	3.9	7.6	3.7		
30	8.8	6.6	8.6	5.1	8.6	7.3	8.5	5.6	8.3	6.8	8.3	7.8	8.2	7.6	8.1	5.4	8.0	5.1	8.0	6.4	7.9	4.9	7.7	6.4	7.6	5.1	7.5	4.1	7.5	5.8		
35	8.6	7.0	8.6	10.2	8.5	8.0	8.4	7.5	8.2	8.7	8.1	6.1	8.1	5.1	8.0	7.3	8.0	7.6	7.9	7.0	7.8	7.6	7.6	7.8	7.5	7.0	7.5	4.5	7.4	4.7		
40	8.6	9.7	8.5	9.9	8.4	7.5	8.3	12.4	8.2	7.6	8.1	6.8	8.0	9.2	8.0	14.8	7.9	5.8	7.8	5.8	7.7	6.4	7.6	6.1	7.5	10.7	7.4	4.9	7.3	7.3		
	16 日		17 日		18 日		19 日		20 日		21 日		22 日		23 日		24 日		25 日		26 日		27 日		28 日		29 日		30 日		31 日	
0.5	7.7	1.2	7.7	1.3	7.6	1.6	7.6	1.0	7.8	1.0	7.8	0.8	7.7	0.8	7.8	0.8	7.8	0.8	7.8	0.8	7.6	0.8	7.6	1.0	7.5	1.0	7.4	1.0	7.3	1.0	7.3	1.2
1	7.7	1.3	7.7	1.3	7.6	1.3	7.6	1.0	7.8	1.0	7.8	0.8	7.7	0.8	7.8	0.8	7.8	1.0	7.8	0.8	7.6	1.0	7.6	1.0	7.5	1.0	7.4	1.3	7.3	1.3	7.3	1.0
2	7.7	1.3	7.7	1.6	7.6	1.3	7.6	1.0	7.8	1.0	7.8	0.8	7.7	1.0	7.8	0.8	7.8	1.0	7.8	1.0	7.6	0.8	7.6	1.0	7.5	1.0	7.4	1.0	7.3	1.3	7.3	1.3
3	7.7	1.3	7.7	1.6	7.6	1.3	7.6	1.2	7.8	1.0	7.8	1.0	7.7	1.0	7.8	1.0	7.8	0.8	7.8	0.8	7.6	0.8	7.6	1.2	7.5	1.0	7.4	1.0	7.3	1.3	7.3	1.0
4	7.7	1.3	7.7	1.6	7.5	1.6	7.6	1.0	7.8	1.3	7.8	1.2	7.7	1.2	7.8	1.0	7.8	1.0	7.8	0.8	7.6	1.0	7.6	1.3	7.5	1.2	7.4	1.3	7.3	1.3	7.3	1.2
5	7.7	1.3	7.7	1.6	7.5	1.3	7.6	1.2	7.7	1.3	7.8	1.0	7.7	1.0	7.8	1.0	7.8	0.8	7.8	1.3	7.6	1.0	7.6	1.2	7.5	1.0	7.4	1.2	7.3	1.0	7.3	1.0
6	7.7	1.3	7.7	1.6	7.5	1.6	7.6	1.0	7.7	1.3	7.7	1.0	7.7	1.0	7.8	1.2	7.8	1.0	7.8	1.0	7.6	1.0	7.6	1.2	7.5	1.0	7.4	1.0	7.3	1.3	7.3	1.0
7	7.7	1.3	7.7	1.6	7.6	1.6	7.6	1.0	7.7	1.3	7.7	1.0	7.7	0.8	7.8	1.0	7.8	0.8	7.8	1.0	7.6	1.2	7.6	1.2	7.5	1.3	7.4	1.0	7.3	1.0	7.3	1.3
8	7.7	1.3	7.7	1.6	7.6	1.3	7.6	1.3	7.7	1.3	7.7	1.2	7.7	1.0	7.8	0.8	7.8	0.8	7.8	1.3	7.6	0.8	7.6	1.0	7.5	1.0	7.4	1.2	7.3	1.2	7.3	1.2
9	7.7	1.6	7.7	1.6	7.5	1.6	7.6	1.3	7.6	1.3	7.7	1.0	7.7	1.0	7.7	1.0	7.8	1.0	7.8	1.3	7.6	1.2	7.6	1.2	7.5	1.0	7.4	1.3	7.3	1.3	7.3	1.0
10	7.7	1.3	7.7	1.6	7.5	1.3	7.6	1.3	7.6	1.3	7.6	1.0	7.7	1.3	7.6	1.0	7.7	1.0	7.7	1.0	7.6	1.0	7.6	1.3	7.5	1.3	7.4	1.3	7.3	1.3	7.3	1.3
12	7.7	1.3	7.7	1.6	7.5	1.3	7.5	1.6	7.6	1.3	7.6	1.2	7.6	1.2	7.6	1.3	7.7	1.3	7.6	1.3	7.6	1.3	7.6	1.3	7.5	1.0	7.4	1.3	7.3	1.3	7.3	1.3
14	7.7	1.3	7.7	1.6	7.5	1.3	7.5	1.3	7.5	1.6	7.5	1.3	7.5	1.3	7.5	1.3	7.5	1.2	7.5	1.0	7.6	1.0	7.6	1.3	7.5	2.4	7.3	1.6	7.3	1.6	7.2	1.3
16	7.7	2.7	7.7	1.6	7.5	1.3	7.5	1.3	7.5	1.6	7.4	2.0	7.5	1.6	7.4	1.6	7.4	1.6	7.4	1.6	7.5	1.3	7.5	2.0	7.4	2.4	7.3	1.3	7.3	1.8	7.2	1.3
18	7.6	2.2	7.6	2.0	7.5	1.3	7.5	2.2	7.5	2.4	7.4	2.0	7.4	2.0	7.4	3.0	7.3	3.5	7.3	2.4	7.4	1.6	7.5	2.4	7.3	2.4	7.2	2.4	7.2	1.6	7.2	1.6
20	7.6	2.9	7.6	2.9	7.5	2.0	7.5	2.2	7.4	3.0	7.3	2.7	7.4	2.4	7.3	3.0	7.3	2.9	7.3	2.4	7.3	1.6	7.4	2.7	7.3	2.7	7.2	3.7	7.2	2.7	7.2	2.4
25	7.5	2.7	7.5	3.7	7.4	3.0	7.3	4.1	7.3	3.7	7.2	3.5	7.3	3.0	7.2	3.0	7.2	3.2	7.2	3.7	7.2	2.2	7.2	3.0	7.2	4.5	7.1	4.5	7.1	5.6	7.1	7.0
30	7.4	3.7	7.4	5.1	7.3	3.7	7.2	6.6	7.2	4.1	7.1	4.9	7.1	4.1	7.1	4.3	7.1	3.5	7.1	4.1	7.1	4.1	7.1	5.8	7.1	7.6	7.1	9.2	7.1	7.5	7.1	6.1
35	7.3	4.3	7.3	5.8	7.2	5.8	7.1	6.6	7.1	7.0	7.1	4.5	7.1	5.6	7.1	7.6	7.1	7.0	7.1	6.8	7.1	6.0	7.1	8.7	7.1	10.6	7.1	7.8	7.1	7.6	7.1	7.6
40	7.2	4.1	7.2	9.3	7.2	6.8	7.0	6.6	7.1	7.6	7.0	9.2	7.0	6.8	7.1	12.4	7.1	9.9	7.1	9.5	7.1	8.7	7.1	8.9	7.1	9.3	7.1	10.6	7.1	7.0	7.1	9.2



▲永瀬ダム周辺 位置図



▲自動濁度計 全景

永瀬ダム堰堤上流付近に台船を浮かべ、その上に自動で濁度を取得する装置を設置しています。

毎日朝9時になると測定器を沈め、設定された深度における濁度を計測しています。