

2025 年 8 月 永瀬ダム 自動濁度装置 測定結果一覧表

※濁度測定器は、ホルマジン標準液（FTU）を使用して校正しています。

自動濁度計設置場所

	1 日		2 日		3 日		4 日		5 日		6 日		7 日		8 日		9 日		10 日		11 日		12 日		13 日		14 日		15 日	
水深	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度
0.5	27.5	1.2	27.8	0.8	28.2	1.0	28.2	1.2	28.1	0.8	28.2	0.8	28.6	0.8	27.7	0.3	27.1	0.3	26.3	0.3	22.3	59.9	21.5	81.0	20.5	63.9	20.7	44.6	21.2	25.2
	27.5	0.8	27.8	0.8	28.2	0.8	28.2	1.0	28.1	0.8	28.2	0.8	28.6	0.8	27.7	0.3	27.1	0.3	26.3	0.3	22.3	63.0	21.5	85.8	20.5	58.8	20.8	42.7	21.6	26.6
2	27.5	1.0	27.8	1.0	28.2	1.0	28.2	1.2	28.1	1.0	28.3	0.8	28.6	0.8	27.7	0.3	27.1	0.3	26.4	0.3	22.3	69.7	21.5	92.6	20.6	64.0	21.0	49.0	22.7	36.2
3	27.5	1.3	27.8	1.3	28.2	1.3	28.2	1.3	28.1	1.3	28.2	1.0	28.6	1.0	27.7	0.8	27.1	0.8	26.4	0.3	22.3	84.9	21.5	93.5	20.6	63.7	20.9	50.0	22.6	39.2
4	27.5	1.3	27.8	1.3	28.2	1.3	28.2	1.3	27.6	1.0	27.3	1.0	28.0	1.0	27.4	0.8	26.7	0.8	25.7	0.5	22.3	80.3	21.3	104.2	20.6	64.0	20.8	52.1	21.4	36.0
5	27.0	1.3	27.1	1.2	27.7	1.0	27.6	1.3	26.0	1.3	25.5	1.0	26.3	1.0	26.1	0.8	25.4	0.8	24.7	0.3	22.1	82.8	21.1	113.6	20.6	68.5	20.5	50.0	20.7	45.2
6	25.7	1.3	25.5	1.8	26.2	1.6	25.9	1.3	24.5	1.0	24.1	1.0	24.9	1.0	24.9	0.8	24.3	0.8	24.0	0.8	21.9	79.3	20.9	109.4	20.5	71.6	20.4	51.1	20.4	43.4
7	24.3	1.6	24.1	1.3	24.6	1.2	24.4	1.2	23.4	1.0	23.2	1.0	23.9	0.8	24.0	0.8	23.6	0.8	23.5	0.8	21.6	76.5	20.8	117.5	20.5	81.6	20.3	53.6	20.2	45.9
8	23.2	1.6	23.0	1.3	23.3	1.3	23.3	1.2	22.7	1.0	22.6	1.0	23.3	0.8	23.4	0.8	23.1	0.8	23.0	0.8	21.4	75.1	20.7	126.9	20.5	79.7	20.2	50.0	20.2	44.4
9	22.3	1.8	22.3	1.3	22.5	1.3	22.5	1.0	22.1	1.0	22.2	1.0	22.7	0.8	22.8	0.8	22.7	0.8	22.6	0.5	21.1	84.1	20.7	157.0	20.4	65.3	20.1	53.6	20.1	40.6
10	21.7	2.0	21.7	1.6	21.9	1.3	21.9	1.3	21.7	1.0	21.8	0.8	22.3	0.8	22.4	0.8	22.3	0.8	22.3	0.8	20.8	109.5	20.6	151.2	20.4	73.4	20.1	49.9	20.0	38.4
12	20.8	3.5	21.0	2.9	21.2	3.0	21.2	2.0	21.0	1.6	21.0	1.3	21.6	1.2	21.8	0.8	21.7	0.8	21.8	1.3	20.4	126.9	20.3	127.8	20.3	87.8	19.9	49.7	19.9	45.4
14	20.2	8.9	20.4	8.9	20.6	8.3	20.5	7.8	20.4	8.0	20.3	5.1	20.9	5.4	21.0	3.9	20.8	3.5	21.1	3.5	19.8	72.8	20.0	153.4	20.1	66.8	19.8	56.2	19.9	43.4
16	19.5	13.1	19.6	11.4	19.7	12.4	19.5	13.3	19.4	12.4	19.2	11.2	19.9	9.9	19.9	8.7	19.6	8.7	19.6	7.6	19.3	113.1	19.7	171.4	19.8	102.9	19.6	72.2	19.7	47.5
18	18.8	17.7	18.8	17.2	18.8	17.4	18.6	15.8	18.4	14.8	18.2	13.3	18.9	13.1	18.8	11.6	18.6	10.6	18.4	9.9	18.6	143.0	19.3	136.5	19.6	112.7	19.5	78.1	19.5	55.9
20	18.1	17.0	17.9	16.0	17.7	13.1	17.3	10.7	17.1	11.4	16.3	7.8	17.6	9.2	17.3	7.5	16.5	5.4	16.4	6.4	18.0	138.4	18.7	85.1	18.6	73.8	19.0	64.0	19.1	60.7
25	12.7	7.5	11.8	6.8	11.5	6.8	11.7	6.8	10.7	6.4	9.8	5.8	11.0	5.8	10.7	5.8	9.4	6.0	9.6	5.8	11.7	8.7	11.4	12.9	11.7	13.1	11.5	13.1	10.0	12.4
30	9.3	5.6	8.7	5.6	8.8	5.8	8.7	5.4	8.2	5.1	7.7	4.7	8.1	4.9	8.0	5.1	7.8	4.7	7.7	4.7	8.0	6.4	8.2	7.0	8.2	7.3	8.2	7.6	7.9	6.4
35	8.0	4.7	7.7	5.1	7.9	4.9	7.8	4.5	7.6	4.7	7.4	4.5	7.5	5.6	7.6	5.4	7.5	4.7	7.5	4.7	7.6	5.1	7.6	6.4	7.7	6.8	7.7	7.0	7.6	6.1
40	7.7	9.5	7.5	4.7	7.6	5.4	7.5	5.1	7.5	4.5	7.4	3.9	7.5	6.6	7.5	5.4	7.4	5.1	7.5	4.5	7.5	5.8	7.5	6.8	7.6	7.8	7.6	7.0	7.5	6.0

	16 日		17 日		18 日		19 日		20 日		21 日		22 日		23 日		24 日		25 日		26 日		27 日		28 日		29 日		30 日		31 日	
水深	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度	水温	濁度
0.5	24.9	17.9	25.4	16.7	21.3	17.9	21.3	13.3	23.4	6.1	25.6	4.7	25.5	3.5	25.2	3.0	24.5	2.7	25.6	2.4	26.0	2.4	26.2	2.0	27.0	2.0	27.1	2.0	27.4	1.8	27.6	2.0
1	25.1	19.3	25.5	13.7	21.4	13.1	21.6	14.5	23.6	5.6	25.6	4.3	25.6	3.5	25.2	3.0	24.6	2.4	25.8	2.0	26.0	2.4	26.3	2.4	27.0	2.0	27.2	2.0	27.4	2.0	27.7	1.6
2	25.3	20.0	25.8	15.4	22.4	30.0	22.6	32.3	24.2	8.9	25.7	4.7	25.9	5.1	25.4	4.1	25.1	4.5	26.4	4.3	26.2	2.9	26.5	2.7	27.0	2.4	27.2	2.2	27.4	2.0	27.7	1.8
3	25.4	29.0	25.8	28.0	22.2	30.2	22.8	42.1	24.4	28.0	25.7	18.6	25.9	15.4	25.4	13.5	25.4	12.6	26.6	10.6	26.5	8.9	26.7	6.0	27.0	4.9	27.3	3.9	27.4	3.0	27.7	2.7
4	23.9	37.4	24.4	33.8	21.3	31.1	21.6	46.9	23.3	31.4	24.9	22.5	24.7	19.8	25.0	18.9	24.4	15.8	25.3	14.5	26.1	11.6	26.2	9.3	26.5	7.0	27.0	5.4	27.2	4.3	27.4	3.0
5	21.9	38.8	22.3	37.1	20.8	30.2	21.0	42.1	21.9	34.8	22.9	22.5	22.7	21.8	23.6	18.7	22.6	15.4	23.5	15.4	24.7	13.9	24.8	12.1	24.9	8.3	25.5	7.0	26.0	5.6	25.9	4.1
6	20.9	38.1	21.2	36.5	20.6	28.5	20.7	46.5	21.1	33.8	21.6	29.4	21.5	22.0	22.3	19.8	21.6	18.3	22.2	16.0	23.3	14.8	23.4	12.3	23.4	9.7	23.9	8.3	24.5	6.1	24.2	5.6
7	20.5	37.7	20.7	35.7	20.5	26.8	20.5	47.8	20.8	32.5	21.0	24.4	20.9	25.6	21.5	20.0	20.9	17.2	21.4	15.8	22.3	11.8	22.4	12.9	22.3	10.4	22.7	8.5	23.3	7.6	22.9	5.8
8	20.3	38.1	20.4	37.1	20.4	25.4	20.4	38.1	20.6	31.2	20.6	25.2	20.6	23.5	21.0	19.6	20.6	17.2	20.9	15.5	21.7	12.3	21.6	11.2	21.5	10.4	21.8	9.5	22.4	8.3	22.1	6.8
9	20.2	36.5	20.3	36.9	20.4	26.8	20.3	46.8	20.4	35.0	20.5	29.2	20.4	20.6	20.7	18.7	20.4	17.0	20.6	14.5	21.2	13.7	21.1	11.4	21.0	11.0	21.3	10.4	21.7	8.9	21.6	7.3
10	20.1	37.1	20.2	34.6	20.3	29.5	20.2	37.7	20.3	32.1	20.4	28.5	20.3	20.6	20.5	19.3	20.3	17.2	20.4	16.0	20.8	13.7	20.8	12.4	20.7	11.2	20.9	10.4	21.2	9.5	21.2	7.8
12	20.0	36.0	20.1	32.1	20.1	32.7	20.1	46.8	20.2	36.5	20.2	33.3	20.2	30.0	20.3	26.3	20.2	21.2	20.3	18.7	20.5	16.9	20.4	14.1	20.4	13.9	20.5	12.3	20.7	11.6	20.7	11.0
14	20.0	39.2	20.0	34.2	20.0	34.0	20.0	39.8	20.1	37.7	20.1	35.7	20.1	31.1	20.2	30.6	20.2	28.5	20.2	26.1	20.3	22.7	20.3	23.3	20.2	20.6	20.3	20.1	20.4	18.7	20.4	17.2
16	19.8	43.0	19.9	35.8	19.9	35.2	19.9	34.2	19.9	34.2	20.0	31.9	19.9	30.6	20.0	31.4	20.0	29.2	20.0	26.8	20.2	26.8	20.1	26.3	20.1	25.2	20.0	22.7	20.2	25.2	20.1	22.3
18	19.6	51.1	19.7	40.8	19.7	40.0	19.7	42.7	19.8	38.1	19.8	38.9	19.8	34.0	19.8	39.6	19.8	40.6	19.8	35.0	20.0	36.2	19.8	36.0	19.7	33.3	19.7	32.3	19.8	31.2	19.6	27.5
20	19.3	60.5	19.5	57.4	19.5	51.7	19.5	48.3	19.5	46.8	19.5	47.3	19.4	39.2	19.4	34.8	19.2	30.4	19.3	29.4	19.3	25.8	19.1	24.9	19.0	26.4	18.7	23.7	18.8	22.5	18.0	21.7
25	12.0	12.1	14.3	17.7	13.9	17.7	13.8	18.6	13.7	16.0	13.3	15.0	12.7	14.1	13.5	12.6	12.3	12.1	12.9	12.6	11.7	11.2	12.8	10.7	12.4	10.4	12.5	9.9	13.0			